




### Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332



If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box. If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- · Can be used immediately and accessed again later
- Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Physical data	
Width	45.9 mm / 1.807 inches
Height	17.8 mm / 0.701 inches
Depth	33.6 mm / 1.323 inches

Mechanical data	
Design	Size 2
Mounting type	Flying leads
Suitable	for 4 mm <sup>2</sup> splicing connectors

Material data	
Note (material data)	
	Information on material specifications can be found here
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	18.4 g

Environmental requirements	
Ambient temperature (operation)	-55 +85 ℃
Ambient temperature (storage)	0+40 °C

Commercial data	
ETIM 8.0	EC001170
ETIM 7.0	EC001170
PU (SPU)	48 (4) pcs
Country of origin	DE
GTIN	4055143998017
Customs tariff number	85389099990



## Data Sheet | Item Number: 207-1332

Standard

https://www.wago.com/207-1332

#### **Environmental Product Compliance**

**RoHS Compliance Status** 



Compliant,No Exemption

#### Approvals / Certificates

#### General approvals

VDE	
Approval	

VDE EN 60998 VDE Prüf- und Zertifizierungsinstitut

Certificate I	Vame
400051938	

#### Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-

Downloads
Environmental Product Compliance
Compliance Search
Environmental Product Compliance 207-1332

#### Documentation

System Description			Bid Text		
System Description 207 Series Gel boxes	pdf 1156.45 KB	$\downarrow$	207-1332	xml 3.58 KB	$\downarrow$
System Description 207 Series Gel boxes	pdf 1191.37 KB	$\downarrow$	207-1331	docx 20.38 KB	$\downarrow$

CAD/CAE-Data	
CAD data	CAE data
2D/3D Models 207-1332	ZUKEN Portal 207-1332

#### Installation Notes

Installation



Open the Gelbox at the side latches.



Place the wired connector in the Gelbox.



Place the wired connector in the Gelbox.



Close the Gelbox.

# Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332

#### Installation



Close latch securely.

- Re-accessible:
- Open the Gelbox.
- Remove the gel. Rewire with new components.







Lift the flap and pull the cover perforation forward.

Press in the perforation on the sides.

Tear off the cover from the perforation.



As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out



If the flap is not required, tear off from the perforation.



Subject to changes. Please also observe the further product documentation!